

Pre Bid Meeting Date: 21-March-2023

Venue: ICAT Centre – 1, Plot No. 26, Sector – 3, HSIIDC, IMT Manesar, Gurugram 122051

Tender Reference No. ICAT/T/CIVIL/ACHMB/2022-23/220

CPP Tender ID: 2023_DHI_702627_1 Dated: 6-March-2023

Tender Detail: Supply, Installation, Testing & Commissioning of Acoustic Chamber inside B4 Building at ICAT Centre – 1, Manesar (Haryana).

Please find below ICAT reply on technical queries raised by the bidders in pre-bid meeting held at ICAT Centre – 1 on dated 21st March' 2023 for tender **“Supply, Installation, Testing and Commissioning of Acoustic Chamber Inside B4 Building at ICAT Centre – 1, Manesar, Tender Reference No. ICAT/T/CIVIL-C1/ACHMB/2022-23/220”**

| Pre Bid Meeting Minutes Of Meeting | | |
|--|---|--|
| Name Of Work: “Supply, Installation, Testing and Commissioning of Acoustic Chamber Inside B4 Building at ICAT Centre – 1, Manesar, Tender Reference No. ICAT/T/CIVIL-C1/ACHMB/2022-23/220”. | | |
| Date : 23.03.3023 | | |
| S. No. | Query raised by Bidder | Reply By ICAT |
| 1 | Provision of Air Ventilation System in enclosure | Provision of ducting to be considered by bidder. However exhaust arrangements are not in scope of bidder |
| 2 | Thickness of the G.I. Perforated Sheet should be 1 mm. | As per tender the thickness of inner sheet is 0.4 MM. However dents and undulations will not be accepted. Hence in case bidder consider they will not able to provide the surface without dents and undulations in 0.4 mm sheet, they may use thicker sheets. No undulations / dents will be accepted. |
| 3 | Warranty | Bidder has to provide 24 months warranty against complete assembly |
| 4 | Completion Period | Project completion period will be 45 days from the date of Notice to proceed. |