

Pre Bid Meeting MOM

Pre Bid Meeting Dated: 4-September-2023

Venue: PE Meeting Room, ICAT Centre – 2, Plot No. 1, Sector – M11, Near Maruti Gate No. 4, IMT Manesar, Gurugram 122051 (Haryana)

Tender/NIT Reference No. ICAT/T/PE-C2/CLN-HSD&PT/2023-24/66

CPPP Tender ID: 2023_DHI_723190_1 Dated: 14th August' 2023

Please find below ICAT reply on technical queries raised by the bidders in pre-bid meeting held at ICAT Centre – 1 on dated 4th September' 2023 for tender “HSD & Petrol Tank Cleaning and Associated Work at ICAT Centre – 2, Manesar, Tender Reference No. ICAT/T/PE-C2/CLN-HSD&PT/2023-24/66”

Pre Bid Meeting MOM		
Tender Description: HSD & Petrol Tank Cleaning and Associated Work at ICAT Centre - 2, Manesar (Haryana)		
Dated: 4-September-2023		
SI No.	Queries by Bidder/Participant	Remarks/Reply by ICAT
1	Will there be any sample testing of HSD?	Yes, Fuel samples to be tested before and after the cleaning and it will be under the scope of successful bidder. Testing may be done from any Govt. Accredited Lab.
2	Pneumatic Testing to be done by third party or vendor?	It can be done either by the vendor or any competent 3rd party. Report for the same need to be submitted. All should in in line with PESO regulations.
3	Any requirement for the calibration of Testing Equipment	All measuring/other test to be performed by calibrated equipment and calibration report of equipment used for testing also need to be submitted along with the test report to ICAT.

It is mandatory for the bidder to accept, duly sign and submit this pre-bid MOM Document along with Bid Documents.

Rest all other term and conditions will remain the same.