

Dated: 26-Sept-2023

**Pre Bid Meeting MOM**

**Pre-Bid Meeting Dated:** 26-September-2023 (15:00 Hrs)

**Venue:** PE Meeting Room, ICAT Centre – 2, Plot No. 1, Sector – M11, Near Maruti Gate No. 4, IMT Manesar, Gurugram 122051 (Haryana)

**Tender/NIT Reference No.** ICAT/T/PE-C2/PNG/2023-24/75

**CPPP Tender ID:** 2023\_DHI\_726690\_1 Dated: 11-Sept-2023

Please find below ICAT reply on technical queries raised by the bidders in pre-bid meeting held at ICAT Centre – 2 on dated 26<sup>th</sup> September’ 2023 for tender “Supply, Installation, Testing and Commissioning of PNG Pipeline & Allied Work from Meter Outlet to 2 X 1250 kVA DG Sets at ICAT Centre – 2, Manesar, Tender Reference No. ICAT/T/PE-C2/PNG/2023-24/75”

<b>Pre-Bid MOM</b>					
<b>Tender Description: Supply, Installation, Testing and Commissioning of PNG Pipeline &amp; Allied Work from Meter Outlet to 2 X 1250 kVA DG Sets at ICAT Centre – 2, Manesar, Tender Reference No. ICAT/T/PE-C2/PNG/2023-24/75</b>					
<b>Dated: 26-September-2023 (17:00 Hrs), Venue: PE Meeting Room at ICAT Centre - 2, Manesar (Haryana)</b>					
<b>Sr. No.</b>	<b>File Name</b>	<b>Page No.</b>	<b>Clause No.</b>	<b>Queries</b>	<b>Clarification by ICAT</b>
<b>Technical Queries</b>					
1	Tender Document (75-202324)	26	S. No. 3 & 4	Ball valve size shown in S.No 3 & 4 are same - 50mm NB (2"). Please Clarify.	Please consider Sr. No. 3 as 80 mm (3"), Quantity 1 Nos. and Sr. No. 4 as 50 mm (2") Quantity 2 Nos. This is a typographical error.
<b>Commercial Queries</b>					
1	Tender Document (75-202324)	33	Annexure-D	Is this Fixed Price Contract or quantity based. There are no any provision for quantity measurement. What if quantity increased or decreased or any additional material required during installation? Please clarify	For any addition in quantity successful contractor would require to submit the estimation for approval from ICAT management. Decrease in quantity can be billed directly as per PO terms.
2	Tender Document (75-202324)	33	S. No. 3 & 4	Ball valve size shown in S. No 3 & 4 are same - 50mm NB (2"). Please Clarify.	Please consider Sr. No. 3 as 80 mm (3"), Quantity 1 Nos. and Sr. No. 4 as 50 mm (2") Quantity 2 Nos.
3	Tender Document (75-202324)	35	S. No. 3 & 4	Ball valve size shown in S. No 3 & 4 are same - 50mm NB (2"). Please Clarify.	This is a typographical error.

Dated: 26-Sept-2023

4	Tender Document (75-202324)	36	Form 3	Do we need to submit Performance Bank Guarantee along with tender submission or after project award, Please clarify?	PBG need to be submitted post award of the tender only by the successful bidder.
5	Tender Document (75-202324)	33	Annexure-D	Typographical Error in Heading "Proposal Invited for "HSD Tank Cleaning and Associated work at ICAT, Centre - 2, Manesar, Gurugram (Haryana)"	Correct Heading Is "Financial Bid For SITC of PNG Pipeline & Allied Work From Meter Outlet To 2 X 1250 kVA DG Sets At ICAT Centre - 2, Manesar (Haryana)"
5	Tender Document (75-202324)	34 & 35	Annexure-D	Repetition of Activity SI No. 9 of Part A "Supply Part" & Part B "Installation, Testing, Commissioning and Testing Part" <b>Activity Mentioned In SI No. 9 is "80mm NB (3") Pipe Installation Charges"</b>	Due to the repetition of SI No. 9 in both Part A & B, therefore SI No. 9 Activity Mentioned in Part A now Stands Null & Void. Hence bidders are requested to please fill you a price on Part B only for the said activity. If Any bidder fills their price for Activity SI No. 9 in both Part A & B, in that case only Part B price for Activity SI No. 9 would be considered during the financial evaluation and Part A of the said activity will not be considered.

**It is mandatory for the bidder to accept, duly sign and submit this pre-bid MOM Document along with Bid Documents.**

**Rest all other term and conditions will remain the same.**